



**GOVERNMENT OF KARNATAKA
(DEPARTMENT OF ELECTRICAL INSPECTORATE)**

No: DEI/KLR/FITNESS-CERT/23-24/1522

O/o Deputy Electrical Inspector,
No: 2961, New Extension,
Kolar District-563101

Dt: 16/03/2024

To,
The Jain International School,
Krishnapuram Village, Oorgaumpet Post,
Kolar Gold Fields-563121.

Sir,

Sub: Verification of compliance report pertaining to electrical installation of 1x100KVA, 11KV/433V Transformer Sub Station bearing BESCOM R R No: KGFHT-154 and 1x30KVA , 415V DG set at The Jain International School, Krishnapuram Village, Oorgaumpet Post, Kolar Gold Fields – Reg

- Ref:1. T.O. Ltr. No. DEI/KLR/PI/SPOT/2023-24 Dt: 07.03.2024 periodical inspection report.
2. Your Ltr. No. NIL Dt. 16.03.2024 compliance report through M/s. Dhanalakshmi Electricals.
3. Your Ltr. No. NIL Dt: 05.03.2024 this office received on 16.03.2024 requesting for fitness certificate.

With reference to the above on specific request from consumer vide letter under ref(3) verification of compliance pertaining to electrical installation of 1x100KVA, 11KV/433V Transformer Sub Station bearing BESCOM R R No: KGFHT-154 and 1x30KVA , 415V DG set at The Jain International School, Krishnapuram Village, Oorgaumpet Post, Kolar Gold Fields found that Yard fencing is found to be in general conformity with 49(ii) of CEA Regulation 2010.

Further inspection fees of **Rs. 700/- (inwords: Seven Hundred only)** paid
Ch. No. CR0324004300198381 Dt: 16.03.2024 is hereby acknowledged.

Yours faithfully,


Deputy Electrical Inspector,
Kolar
KOLAR

Copy to:
I.O.C. & M.F.